

BUREAU VERITAS
Certification



Certificate of Conformity

Awarded to:

SAINT-GOBAIN PAM CANALISATION
Local Company : Saint-Gobain PAM Italia S.r.l.

Factory: LAVIS - Via Galvani, 6 - 38015 Lavis (TN) - ITALY

Bureau Veritas Italia S.p.A. certify that the following products:

Valves for water pipelines or sewerage pipelines

Commercial brands:

EUROSTOP series
Eurostop NG design
PN 10: from DN 900 to DN 2000
PN 16: from DN 800 to DN 2000
PN 25: from DN 700 to DN 1800

Eurostop NGL design
PN 10: from DN 150 to DN 800
PN 16: from DN 150 to DN 700
PN 25: from DN 150 to DN 600

Ventex
DN 50,60 65, 80,100, 150, 200
PN 10/16/25
4000D & 4000S **6000D & 6000S**
DN 50, 60, 65 DN 80
PN 10/16/25 PN 10/16/25

9000D & 9000S
DN 100, DN 150
PN 10/16/25
Type 100
Models 110, 111, 112, 113
PN 10/16/25

E2001 ACV
from DN 50 to DN 700
PN 10/16/25
E508 NGL Needle Valves
PN 10/16: from DN 100 to DN 1600
PN 25: from DN 100 to DN 1000

designed and produced by SAINT-GOBAIN PAM CANALISATION
have been evaluated and found in conformity against the requirements of the following standards:

Isolating valves

EN 1074-1: 2000, EN 1074-2: 2000 Valves for water supply, fitness for purpose requirements and appropriate verification tests - Part 1: general requirements, Part 2: isolating valves

EN 593:2017 Industrial valves - Metallic butterfly valves for general purposes*


* Not to be intended nor to be used with reference and/or in relation to the Directive 2014/68/EU (Pressure Equipment Directive)

Air valves

EN 1074-1: 2000, EN 1074-4: 2000 Valves for water supply, fitness for purpose requirements and appropriate verification tests - Part 1: general requirements, Part 4: air valves

Control valves

EN 1074-1: 2000, EN 1074-5: 2001 Valves for water supply, fitness for purpose requirements and appropriate verification tests - Part 1: general requirements, Part 5: control valves

These products belong to family 
Certification according to requirements stated in:

QHSE-REG-02.TQR Bureau Veritas
IND-REP-48-CP Bureau Veritas

Original Emission Date: 21/12/2006
Last Emission Date: 28/02/2025
Expiration Date: 25/01/2028

Subject to the continued satisfactory operation, to check this certificate validity please refer to website: www.bureauveritas.it.
Further clarifications regarding the scope of this certificate and the applicability of standard's requirements may be obtained by consulting the organisation.

Scheme Technical Manager



Date: 28/02/2025

PRD N°0009

Certificate N°: **1253/010 Rev.3**

Bureau Veritas Italia S.p.A – Viale Monza, 347 – 20126 MILAN - ITALY