

# PAM C 45

## PAMREX 600 / 24 in.

Joint d'étanchéité aux eaux de ruissellement


Secondary seal ( water ingress )

*Mise en place du joint d'étanchéité*

*On site installation instructions  
of the secondary seal*


- Opérer le tampon ouvert dans son cadre en position bloqué à 90°.
- S'assurer de la propreté de la jupe du tampon.
- Mettre en place le joint d'étanchéité.
- Contrôler visuellement le jonc d'insonorisation et le changer si nécessaire. [ Ref jonc = CDPA60EF-L ]

- Install the seal with the cover in open position, blocked at 90° in it's frame.
- Ensure that the cover skirt is clean.
- Install the secondary seal
- Control visually the seating ring, change it if necessary. [ Seating ring ref = CDPA60EF-L ]




Saisir le joint, raccordement vers le haut.

For correct installation the seal "joint" must be located at the top of the cover i.e. at the pry slot.



Mettre en place le joint en commençant coté articulation.

To install the seal start at the hinge side of the cover.



Pousser le joint complètement vers le tampon.

Completely push the seal towards the cover.

L'installation du joint s'effectue sur un tampon parfaitement propre, sans lubrifiant ni outils.

The gasket installation is carried out on a clean cover without lubricant or tools.